

Knowledgebase > easYgen-3000XT > easYgen-2000 application limitation compared to easYgen-3000XT Line

easYgen-2000 application limitation compared to easYgen-3000XT Line

Clemens - 2024-09-27 - easYgen-3000XT

Multiple gensets controlled by easYgen-2000 line controls **cannot** serve GCBs and a MCB because

easYgen-2000 controls not have a bus bar voltage measurement between GCB (Generator Circuit Breaker) and MCB (Mains Circuit Breaker)

