Mssing member {4063} LS5 V2 not recognizing

Simon - 2024-10-10 - LS-5

What you can check is...

- Is the monitoring activated in all LS units?

4060	**Monitoring**	2	On	Multi-unit missing members monitoring is carried out.
			[Off]	Monitoring is disabled.
				Notes This parameter only applies to application mode A02.

- Is the number of LS5 communicating configured correctly in all units?

4060	**Monitoring**	2	On	Multi-unit missing members monitoring is carried out.
			[Off]	Monitoring is disabled.
				Notes This parameter only applies to application mode A02.

- How many units are shown in the multi unit screen?