



ナレッジベース > MFR300 > I cannot change Toolkit MFR300 Parameters in MFR300 kW transducer

I cannot change Toolkit MFR300 Parameters in MFR300 kW transducer

Clemens - 2023-01-20 - MFR300

Go for Code Level 5

Code is **0500**

That shall unlock the locked parameters you cannot access by Level 3..