



[ナレッジベース](#) > [DTSC-200](#) > [Not able to save settings from DTSC-200 \(8440-1868 L\)](#)

Not able to save settings from DTSC-200 (8440-1868 L)

Simon - 2025-09-04 - [DTSC-200](#)

DTSC-200

PN: 8440-1868-L

SW: 5418-6258-E

Message: the generation of a wset file breaks in Toolkit (the file settings were partially read and need to be resaved)

there will be no wset file generated

How to repair device?

1. Execute factory default settings over Toolkit (ID 1704 = Yes, 1701 = Yes) in Code level 5
2. Other possibility:
 - in Toolkit, go to the page Parameter / Configure application / Display options
 - Write the 4 Free message texts with ID 166622, 16623, 16624 and 16625 to any value