Display Calibration easYgen-3x00 controls

Clemens - 2024-09-27 - easYgen-3000

You can adjust display brightness and contrast manually via HMI

or press the STOP button for around 10 seconds, after 7 seconds, auto calibration mode is starting and after 10 seconds display is auto calibrated

		STOP	Selects STOP mode (Hardware button). Pressing the STOP button for at least 10 seconds, restores the default display settings for brightness and contrast.